

Teresa,

Please see main break details below. We flushed last night and have taken 3 coli samples this morning. Results are expected by 2 PM tomorrow.

TYPE	ADDRESS	DATE OCCURRED	TIME OCCURRED	MAIN BREAK ESTIMATED GPM:	MAIN BREAK ESTIMATED LOWEST RECORDED SYSTEM PSI:	MAIN BREAK ISOLATED:	REPAIR STARTED:	REPAIRED AT:	WATER SERVICES OUT OF WATER DURING MAIN BREAK REPAIR	CAUSE
Main break	33717 I St – NE corner of property.	3/28/18	12:52 PM	900	14 PSI	1:26 PM	1:26 PM	4:04 PM repairs complete, began flushing	Approximately 532 services were out of water, approximately 133 full time homes were out of water.	Flushed I Place at 450 gpm, could be a cause.

Thank you,

April Garcia

Water Treatment Plant Operator

Surfside Homeowners Assoc. Water Dept.