

Teresa,

We had a main break Saturday the 23rd. We took 3 investigative coli samples today and expect to have results by Wednesday.

TYPE	ADDRESS	DATE OCCURRED	TIME OCCURRED	MAIN BREAK ESTIMATED GPM:	MAIN BREAK ESTIMATED LOWEST RECORDED SYSTEM PSI:	MAIN BREAK ISOLATED:	REPAIR STARTED:	REPAIRED AT:	WATER SERVICES OUT OF WATER DURING MAIN BREAK REPAIR	CAUSE
Main break	31905 I Street	6/23/18	6:45 AM	unknown	8 PSI	8:30 AM	8:30 AM	2:30 repairs complete, began flushing	The entire system was without water until 8:30 AM when the break was isolated. Approximately 74 water services were without water until the repair was complete at 2:30 PM.	Possibly backwashing carbon filters at 750 gpm on 6/21/18?

Thank you,

April Garcia

Water Treatment Plant Operator

Surfside Homeowners Assoc. Water Dept.
33104 J Place Ocean Park, Wa 98640
Office 360-665-0005 Cell 360-783-2037
Mailing: 31402 H St. Ocean Park WA 98640
Mon – Fri 7:30 – 4:00

Memo to Surfside Members: In addition to backwashing, we did not include in our email to DOH that the water main was located near tree roots which may have caused or contributed to the main break. "Coli" samples are coliform bacteria samples that look for harmful bacteria in the water. Main breaks can allow bacteria to enter the water system. The water crew disinfects the water pipe used for repair and flushes the water main after the repair to reduce the chance of bacteria in the water.