



## *Homeowners Association*

*31402 H Street; Ocean Park, WA 98640*

*(360) 665-4171; (888)815-9446*

*www.surfsideonline.org*

### **Water System Planning Committee Minutes August 12, 2021 10:25 a.m.**

Meeting participants: J. Curran, R. Brambaugh, T. Newman, J. Purdin, K. Smith, G. Gonzalez, J. Rankin, and K. Olds

1. June minutes reviewed.
2. 10-Year Water Plan: Gil reported that Gray and Osborne (G&O) will have finished their review and say they will send the final draft to Surfside by the End of August..
3. Venturi Pilot Study: 4" venturi has been installed and is operation. Water staff is sending data to G&O every week. Small bubbles in water from the venturi is giving the water in distribution a milky appearance.
4. Carbon has been changed in filter #1 (lead pressure vessel). See operations report.
5. Carbon Filter Valves Enclosure: Gil reported that Mike Augustine has started the enclosure and will be completed construction this summer. Note this is without charging Surfside.
6. Chlorine Injection Enclosure: Joe Plahuta (G&O) to contact Scott Pollock (DOH) again. No response has been received from DOH on plans for venting system for chlorine feed.
7. Operations Report:
  - a. Water quality improvement noticeable with change of carbon in Vessel # 1.
  - b. Gil to contact ATEC on our system as the medium has been used for sixteen years. Need to know if media needs to be replaced as treatment for iron and manganese is decreasing. Air from venturi may be effecting filter performance.
  - c. I Street water main replacement has been completed. Staff will begin South End Loop Project (SELP).
  - d. Well J1, which hasn't been used in 25 years, will be decommissioned. Cost will be 5 to 10 thousand dollars. Waiting for DOH and G&O for correct procedure.

Next meeting is Thursday, September 9, 2021 at 10 a.m.

6. Meeting adjourned at 11:45 a.m.